Z3050Q-H, 1/2", ZoneTight Valve








RA
WARRANT

Technical Data	
Service	chilled, hot water, up to 60% glycol
Flow Characteristic	linear
Size [mm]	0.5" [15]
End Fitting	NPT female ends
Body	forged brass
Ball	chrome plated brass
Stem	brass
Seat	Teflon® PTFE
Seat O-ring	EPDM (lubricated)
Body Pressure Rating [psi]	360
Media Temperature Range	36°F to 212°F [2°C to 100°C]
(Water)	
Maximum Allowable Operating	212°F [100°C] *
Temperature	
Media Temperature Limit	250°F [121°C] *
Max Differential Pressure (Water)	40 psi
Close-Off Pressure	75 psi
Cv	2.7
Weight	0.4 lb [0.2 kg]
Leakage	0%
Servicing	maintenance free

^{*} If temperature exceeds 212°F operating range due to a boiler control failure the valve will safely contain the expense of others.




Application

The QCV zone valves are suited for large commercial buildings where higher close-off and the ability to change flow is desired. Common applications include unit ventilators, fan coil units, VAV reheat coils, fin tube casing, radiant panels and duct coils. The valve fits in space restricted areas and can be assembled without the use of tools.

Suitable Actuators


	Non-Spring	Electronic Fail-Safe	
Z3050Q-H	CQ	CQK	



А	В	С	D	Е	F
4.5" [114]	2.05" [52]	3.83" [97]	2.71" [69]	1.02	" [26]



Z3050Q-H, 1/2", ZoneTight Valve



CQKB24-LL On/Off, Electronic-Fail-safe,24V









24 VAC, ±20%, 50/60 Hz, 24 VDC, ±10%
2.5 W
0.5 W
5 VA (class 2 power source)
3ft [1m], 18 GA plenum cable with 1/2" conduit connector
electronic thoughout 0° to 90° rotation
on/off
90°, adjustable with mechanical stop
pointer
75 sec
<60 sec
2 sec delay before fail-safe activates
5 to 20 seconds
5 to 95% RH non-condensing
35°F to 104°F [1.7°C to 40°C]
-40°F to 176°F [-40°C to 80°C]
IP40, NEMA 2
UL94-5VA
cULus acc. to UL60730-1A/-2-14, CAN/CSA E60730-1:02, CE acc. to 2004/108/EC and 2006/95/EC
max. 35 dB (A)
maintenance free
ISO 9001
0.4 lb [0.2 kg]
IP40

[†] Use flexible metal conduit. Push the listed conduit fitting device over the actuator's cable to butt against the enclosure. Screw in conduit connector. Jacket the actuators input wiring with listed flexible conduit. Properly terminate the conduit in a suitable junction box. Rated impulse Voltage 800V. Type of action 1. Control pollution degree 3.







Wiring Diagrams

X INSTALLATION NOTES



Actuators with appliance cables are numbered.



Actuators may be connected in parallel. Power consumption and input impedance must be observed.



Actuators may also be powered by 24 VDC.



Actuators with plenum cable do not have numbers; use color codes instead.



Meets cULus requirements without the need of an electrical ground connection.



WARNING! LIVE ELECTRICAL COMPONENTS!

During installation, testing, servicing and troubleshooting of this product, it may be necessary to work with live electrical components. Have a qualified licensed electrician or other individual who has been properly trained in handling live electrical components perform these tasks. Failure to follow all electrical safety precautions when exposed to live electrical components could result in death or serious injury.

