



MOUNTING ACCESSORIES AND MOUNTING HEIGHTS



Copyright 2003 Wheelock, Inc. All rights reserved.

Mounting Accessories continued on the next page.

Mounting Accessories continued.



- GENERAL NOTES
- 1. FIGURE B IS TYPICAL OF A STEEL CITY LXM-WOW BOX OR EQUAL. FIGURE B SHOULD BE A 3.5" DEEP BACKBOX FOR CONDUIT INSTALLTIONS AND IS TYPICAL OF A STEEL CITY CY-½ BOX OR EQUAL.
- 2. FIGURE D IS TYPICAL OF A STEEL CITY 52151 BOX OR EQUAL.
- 3. FIGURE E IS TYPICAL OF A STEEL CITY 52171 BOX OR EQUAL.
- 4. FIGURE F IS TYPICAL OF TWO STEEL CITY LXM-WOW BOXES OR EQUAL.
- 5. FIGURE G IS TYPICAL OF A WIREMOLD 5748-2 BOX OR EQUAL.
- 6. FIGURE Q IS TYPICAL OF A STEEL CITY 52171 BOX WITH A STEEL CITY 53151 EXTENSION RING OR EQUAL.

- 7. FIGURE W IS TYPICAL OF A STEEL CITY 72171-1 BOX OR EQUAL.
- 8. USE 3.5 DEEP BACKBOX ON ALL MIZ PRODUCTS WHEN EMT CONDUIT IS USED.
- 9. WHEN USED WITH AC HORN (J), "BB" MUST BE USED FOR SURFACE MOUNT.
- 10. MT OR MTWP STROBE ARE FOR OUTDOOR MOUNTING.
- 11. ONLY E70, ET70, ET-1080, & CH70 PRODUCTS WILL MOUNT TO THE SBB BACKBOX.
- 12. USE WITH SERIES RSSP.
- FIGURE U IS TYPICAL OF A RANDL INDUSTRIES BACKBOX. ("Total Number of conductors shall be in accordance with NEC table 314.16 (B)").

MOUNTING MATRIX

		-	r —	-	-				-										
	SERIES E90/ET90	SERIES RSS/RSSP	SERIES 3IT HORN	SERIES 43T BELLS	SERIES CH	SERIES ET 1010 & 1080	SERIES MB MOTOR BELLS	SERIES E70/ET70	SERIES MIZ/MIZ-TC	SERIES MT	SERIES NH/NS	SERIES HS4/HS	SERIES SM & DSM	SERIES AMT	SERIES AS/AH	SERIES RSSWP ¹ , ASWP ² ,	AHWP ³ , MTWP ⁴ , MT-12/24 ⁴ AND FT70MP ⁴	ERPRO	SERIES RSSR (RED LENS)
(A) UNIVERSAL MOUNTING PLATE															Х				
(B) 1-GANG X2" DEEP - FLUSH (BO) NOTE 1 & 8		Х							Х		Χ				Χ				Χ
(D) 4" X4" X1.5" DEEP - FLUSH (BO) NOTE 2		Χ	Χ	Χ			Χ				Χ				Χ				Х
(E) 4" X4" X2.125" DEEP FLUSH (BO) NOTE 3		Х	Χ	Χ		Х	Χ			Χ				Х	Х				Х
(F) 2-GANG X 3.5" DEEP - FLUSH (BO) NOTE 4 & 8		Χ								Χ		Χ		Х	Χ				Х
(G) 2-GANG X 1.75" DEEP - SURFACE (BO) NOTE 5		Χ									Χ				Х				Х
(H) NATP TRIMPLATE		Χ									Χ				Х				Х
(I) WPBB-R WEATHERPROOF BACKBOX FOR ASWP																	2		
(J) BB SURFACE (WSI) NOTE 9		Χ	Χ	Χ			Χ				Χ				Χ				Χ
(K) WBB WEATHER-PROOF (WSI)			Х	Χ		Х	Χ								Х		3		
(L) ISP2 SURFACE ADAPTER					Χ			Х		Χ		X		Х					
(M) IOB SURFACE & WEATHER -PROOF (WSI) NOTE 10										Χ		X		Х			4		
(N) DBB SURFACE (WSI)		Χ	Х	Χ		Х	Χ			Χ	Χ	X		Х	Χ				Х
(O) RP-R RETROFIT PLATE (WSI)		Χ	Х	Χ	Χ	Х	Χ	Х		Χ				Х	Χ				Χ
(P) SBB SURFACE (WSI) NOTE 11	Х	Χ		Χ	Χ	Х	Χ	Х		Χ	Χ	Χ		Х					Χ
(Q) 4" X4" X2.125" BOX W/ 1.5" EXTENSION RING -FLUSH																			
(BO) NOTE 6	Χ				Χ	Х		Х											
(R) SFP SEMI-FLUSH PLATE (WSI)		Χ	Х	Χ	Х	Х	Χ	Х		Χ	Χ	Χ		Х	Х				Χ
(S) AP ADAPTER PLATE (WSI)				Χ			Χ												
(T) WPSBB-R WEATHERPROOF BACK BOX FOR RSSWP																	1		
(U) 5" SQUARE BACKBOX W/ EXTENSION RING, FLUSH	Х				Χ	Х		Х											
(V) SSB-4 CEILING (WSI) SUPPORT BRIDGE	X				Χ	Х		Х							Х				
(W) 4.6875" X 4.6875" X 2.125" DEEP-SURFACE (BO)													Х						
(X) SHBB (WSI) SHALLOW SURFACE		Х		Χ			Χ				Χ				Х				Χ
(Y) SER SEMI-FLUSH EXTENSION RING (RETROFIT																			
APPLICATIONS)	Х			Χ	Χ			Х											
(Z) SBL-2 SURFACE (WSI) NOTE 12		Х	X	Χ	Х	X	Χ												
DATA SHEET NUMBER(S)	S0310 S1610	S0410	S0500	S0600	S0710	S0800	S1500	S0310 S1610	S1700	S2000	S2100	S2400	S3000	S4000	S8100		S9004		S9008

MOUNTING NOTES

A Caution: The mounting options figures show the maximum number of field wires (conductors) that can enter the backbox used with each mounting option. If these limits are exceeded, there may be insufficient space in the backbox to accommodate the field wires and

stresses from the wires could damage the product. Although the limits shown for each mounting option comply with the National Electrical code (NEC), Wheelock recommends use of the largest backbox option and the use of approved stranded field wires whenever possible, to provide additional wiring room for easy installation and minimum stress on the product from wiring.

Caution: Check that the installed product norm winng.
Caution: Check that the installed product will have sufficient clearance and wiring room prior to installing backboxes and conduit, especially if sheathed multiconductor cable or 3/4" conduit fittings are used.
Mounting hardware for each mounting option is supplied.
Conduit entrances to the backbox should be selected to provide sufficient wiring clearance for the installed product. When extension rings are required, conduit should enter through the backbox, not the extension ring. Use Steel City #53151 (1-1/2" deep) or #53171

(2-1/8" deep) extension rings (as noted in the mounting options) or equal with the same cut-out area. When terminating field wires, do not use more lead length than required. Excess lead length could result in insufficient wiring space 3. for the appliance.

4.

Use care and proper techniques to position the field wires in the backbox so that they use minimum space and produce minimum stress on the product. This is especially important for stiff, heavy gauge wires and wires with thick insulation or sheathing. Do not pass additional wires (used for other than the appliance) through the backbox "unless the backbox is of a sufficient size to permit additional wiring as described in NEC 314.16 (B)". Such additional wires could result in insufficient wiring space for the appliance.

NOTE: Due to continuous development of our products, specifications and offerings are subject to change without notice in accordance with Wheelock Inc. standard terms and conditions.

NFPA-72 Section 4-4.4 "Wall Mounted Appliances shall be mounted such that the entire lens is not less than 80" (2.03m) and not greater than 96" (2.30m)." "Exception: Appliances installed in sleeping areas shall comply with 4-4.4.3." Not included in this document.

ADA 4.28.3 (6) states that "strobes shall be 80" from the finished floor or 6" from the ceiling".

BACKBOX MOUNTING HEIGHTS for WHEELOCK WALL MOUNTED HORIZONTAL STROBE APPLIANCES

			SERIES RS	SP							
	SERIES AS/AH		FLUSH & S	URFACE	SERIES NS	S/NS4	SERIES RS	SS	SERIES MT & AMT		
	AUDIBLE STROBE		RETROFIT	PLATE	HORN STR	ROBE	STROBE		MULTITONE STROBE		
BACKBOX MOUNTING OPTIONS*	80 IN.	6 IN.	80 IN.	6 IN.	80 IN.	6 IN.	80 IN.	6 IN.	80 IN.	6 IN.	
(B) 1-GANG X 2" DEEP - FLUSH (BO)	77 1⁄2"	8 1⁄2"			78 ³ / ₈ "	7 ⁵ / ₈ "	79 ¹ / ₈ "	6 ⁷ / ₈ "			
(D) 4" X 4" X 1.5" DEEP - FLUSH (BO)	77"	9"	83 15/16"		77 ⁷ / ₈ "	8 ¹ / ₈ "	78 ⁵ / ₈ "	-	79 ¹⁵ / ₁₆ "	-	
(E) 4" X 4" X 2.125" DEEP - FLUSH (BO)	77"	9"	83 15/16"		77 ⁷ / ₈ "	8 ¹ / ₈ "	78 ⁵ / ₈ "	7 ³ / ₈ "	79 ¹⁵ / ₁₆ "	6 ¹ / ₁₆ "	
(F) 2-GANG X 3.5" DEEP - FLUSH (BO)	77 1⁄2"	8 ½"			78 ³ / ₈ "	7 ⁵ / ₈ "	79 ¹ / ₈ "	6 ⁷ / ₈ "	80 ⁹ / ₁₆ "	5 ⁷ / ₁₆ "	
(G) 2-GANG X 1.75" DEEP - SURFACE (BO)	77 1⁄2"	8 1⁄2"			78 ³ / ₈ "	7 ⁵ / ₈ "	79 ¹ / ₈ "	6 ⁷ / ₈ "	80 ⁹ / ₁₆ "	5 ⁷ / ₁₆ "	
(M) IOB SURFACE & WEATHER-PROOF (WSI)									79 ³ / ₈ "	6 ⁵ / ₈ "	
(P) SBB SURFACE (WSI)									79 ¼"	6 ¾"	
(Q) 4" X 4" X 2.125" BOX W/ 1.5" EXTENSION RING -FLUSH (BO)											
(U) 5" SQUARE BACKBOX W/ EXTENSION RING, FLUSH (BO)	69½"	8½"	83 ⁷ / ₁₆ "		77 ³ / ₈ "	7 ⁵ / ₈ "	78 ¹ / ₈ "	6 ⁷ / ₈ "	79 ⁷ / ₁₆ "	5 ⁹ / ₁₆ "	
(X) SHBB (WSI) SHALLOW SURFACE	76 ½"	9 1⁄2"			77 ³ / ₈ "	8 ⁵ / ₈ "	78 ¹ / ₈ "	7 ⁷ / ₈ "			
(Y) 4" X 4" X 1.5" BOX W/ 1.5" EXTENSION RING PLATE (BO)											
(Z) SBL-2 SURFACE (WSI)			78"								

			SERIES E	T-1080					SERIES SA	A-70S SELF	
	SERIES C	H70	VANDAL		SERIES E	70	SERIES ET	70	AMPLIFIED SPEAKEF		
	CHIME ST	ROBE	RESISTAN	NT	SPEAKER	STROBE	SPEAKER STROBE		STROBE		
BACKBOX MOUNTING OPTIONS*	80 IN.	6 IN.	80 IN.	6 IN.	80 IN.	6 IN.	80 IN.	6 IN.	80 IN.	6 IN.	
(P) SBB SURFACE (WSI)	77 ¾"	8 ¼"	79 ³ / ₁₆ "	6 ¹³ / ₁₆ "	77 ¾"	8 ¼"	77 ¾"	8 ¼"	79 ³ / ₁₆ "	6 ¹³ / ₁₆ "	
(Q) 4" X 4" X 2.125" BOX W/ 1.5" EXTENSION RING -FLUSH (BO)	78 ½"	7 1⁄2"	80"	6"	78 ½"	7 1⁄2"	78 ½"	7 1⁄2"	80"	6"	
(U) 5" SQUARE BACKBOX W/ EXTENSTION RING- FLUSH (BO)	78"	7"	79½"	5½"	78"	7"	78"	7"	79½"	51⁄2"	
(X) SHBB (WSI) SHALLOW SURFACE											
(Y) 4" X 4" X 1.5" BOX W/ 1.5" EXTENSION RING PLATE (BO)	78 ½"	7 1⁄2"	80"	6"							

* Measured from Bottom of Backbox

NOTES: (BO) = By Others (WSI) = Wheelock Product

WE SUPPORT AND ENCOURAGE NICET CERTIFICATION

MADE IN THE USA

Distributed By:

NATIONAL SALES OFFICE 800-631-2148 Canada 800-397-5777 E-Mail: Info@wheelockinc.com http://www.wheelockinc.com



273 BRANCHPORT AVENUE • LONG BRANCH, NJ 07740 • TEL: 732-222-6880 • FAX: 732-222-2588 S7000 02/04